

		Width of staircase	: 01.60 Mtrs	01.60 Mtrs	01.50 Mtrs	01.50 Mtrs		
		Width of treads	: 30 cms	30 cms	30 cms	30 cms		
		Height of risers	: 15 cms	15 cms	15 cms	15 cms		
		No of riser per flight	: 10 riser per flight	05 riser per flight	14 riser per flight	14 riser per flight		
		Height of handrails	: 00.90 Mtrs	00.90 Mtrs	00.90 Mtrs	00.90 Mtrs		
04	Fire extinguisher	Provided. 05 No's of 04 Kg capacity ABC FE, 03 No's of 06 Kg capacity ABC FE 01 No of 05 Kg capacity ABC FE				01) 06 no's ABC FE each of 5 kg capacity in each floor. 02) 01 No of CO2 extinguisher of 4.5 kg capacity near the Electrical Switch board. 03) 10 No's of sand Bucket for Electrical Switch board. 04) Two number of Hand gloves near the Electrical Switch board. 05) 01 No's Water Mist type extinguishers of 09 liters capacity should be kept near each staircase landing at each floor. 06) 01 No Mechanical Foam FE of 9 Ltrs capacity and 01 No ABC FE of 6 kg capacity should provide near Diesel Generator. [All the extinguishers suggested above should be with B.I.S. markings and should be located at an easily accessible position without obstructing the normal passage and maintained periodically]		
05	Hose reel hose system.	Not Provided.				02 No of Hose reel hose of 30 mtr length with drum and 02		