

			no's delivery hose pipes minimum 2 ½ inch size of adequate length to reach the farthest point of each floor has to be provide with a shut off branch having a nozzle of 2 mm size. The hose reel hose has been connected at each landing by means of an adaptor.
06	Automatic Sprinkler System	Not Provided	Recommended to provide Automatic sprinkler system at each 6.96 Mtrs Cellar Floor
07	At the terrace tank level with minimum pressure of 3.5 kg/cm ²	Not Provided.	Recommended To Provide 01 No pump with minimum pressure of 450 LPM.
08	Diesel generators.	Provided 12 KVA Diesel Generator	it should be connected to alternate power supply in case failure of Electricity.
09	Terrace tank.	02 No's of 2000 Ltrs Capacity Syntax Tank Provided	To Provide Over Head Tank of 10,000 Ltrs for Fire Fighting purpose to be connected to Hose reel hose system.
10	Escape routes	Not Marked	Signage board is required with illuminated points for in which direction to go outside from the building for staff & students and also separate light arrangement to the illumination board by doing from battery operated
11	Fire order (Fire Safety Plans)	Not Displayed	The Notice board have been indicted the action should be taken by the employees in case of any emergency should be displayed with the telephone number of Hosapete Fire Station i.e- 08394-230555 & 101, and the telephone number of nearest Ambulance services and Police Station.